

# **ELECTRICAL SERVICE REQUIREMENTS**

---

## **UNDERGROUND SERVICES, UG**

### **TABLE OF CONTENTS**

<b>TITLE</b>	<b>SECTION NO.</b>
General.....	UG-100
General Requirements.....	UG-101
Point of Service Delivery.....	UG-102
Service Conduits.....	UG-103
Terminating Enclosures .....	UG-104

---

### **LIST OF DRAWINGS**

<b>TITLE</b>	<b>DRAWING NO.</b>
Typical Service Lateral Installation for Single Family Residence .....	UG-DWG-001
Typical Service Conversion from Overhead to Underground .....	UG-DWG-002
Typical Riser at Overhead Distribution Pole.....	UG-DWG-003
Service Entrance for Recessed Service Applications .....	UG-DWG-004
Temporary Service from a Secondary Pull Box .....	UG-DWG-005
Plug-In Temporary (Piggy Back) Service Adapter.....	UG-DWG-006
Riser Sweep Installation at Wall, Pad or Electrical Pull Section .....	UG-DWG-007
Service Entrance for Single Family Dwelling Service .....	UG-DWG-008
Service Pedestal Underground Installation Standards.....	UG-DWG-009
Concrete Handhole/Pull box Installation (Parkway or Sidewalk).....	UG-DWG-010
Nonstandard Terminating Pull Section For Below Ground Level Installation .....	UG-DWG-011

## **Underground Service Availability**

Overhead service will not be supplied to any buildings or premises in an area designated by GWP as an Underground District. In areas where both overhead and underground service facilities exist, GWP shall be consulted for determination of the type of service which will be supplied. In general, an underground service will be required when an underground stub-out is available at the property line. **See GEN-105.** In no case, shall a building be served with two different types of services.

If a residential or multi-residential customer is upgrading an existing overhead electric service to 100A for safety reasons (room additions do not qualify), and is located within the underground district, the customer shall be exempted from converting to an underground service. These services may continue to be served from overhead system and no stub-downs or connection to the underground system is required. However, the panel must be upgraded and replaced with an overhead to underground panel.

If the service is being upgraded to 100A or 200A, and the existing service conduit is undersized (2" or 2 1/2"), special consideration must take place for the undersized service conduit to be utilized. A special letter must be signed by the customer to agree with conditions set forth by GWP. **See UG-100 Page 3 of 3.**

## **Single-Phase Service - 120/240 Volt**

The maximum service size for a single-phase, three-wire, 120/240V service is 400 amperes. *For services larger than 400 amperes, an on-site transformer facility is required. See PRI Section.*

**Three-Phase Service - 240 Volt**

The maximum service size for a three-phase, 240 volt, three-wire delta service is 400 amperes. *For services larger than 400 amperes, an on-site transformer facility is required. See PRI Section.*

In order to avoid the purchase of unsuitable switchgear and/or improper utilization of this service type, close attention must be given to the following:

1. This is not a 4-wire service. No neutral is provided. A fourth service entrance conductor is required as a grounded conductor.
2. Only three-phase balanced loads can be applied to this service. No single-phase load is allowed.
3. Service equipment (meter panels) must be labeled for three-phase, three-wire. This must be stated on the manufacturer's factory supplied label.
4. A bolted in bus link is needed in the metering transformer compartment for each phase.
5. All service equipment must conform to Electrical Utility Service Equipment Requirements Committee (EUSERC) requirements (some manufacturers do not make equipment that conforms to the above requirements).
6. Any questions about the above requirements should be addressed to your service planner at (818) 548-3921.

**Three-Phase Service - 120/240 Volts Four Wire Delta (if available)**

The maximum service size for a three-phase, four-wire 120/240V Delta service is 400 amperes.



To: Glendale Water & Power Department, Electrical Services Division

Subject: Residential Conduit Variance for Underground Electric Service

Since my existing underground electrical service conduit does not meet Glendale *Water & Power's* three inch diameter conduit standards, I, \_\_\_\_\_, the owner of the property located at \_\_\_\_\_ am requesting to continue the use of my existing \_\_\_\_\_ inch electrical service conduit for the proposed upgrade of my existing service panel to \_\_\_\_\_ amps.

I acknowledge that the following conditions must be adhered to by me and my contractor(s) before the Glendale *Water & Power's* electric construction inspector will allow the permanent service cable to be installed. I understand also that Glendale *Water & Power* reserves the right not to accept any stage of the process below:

1. The existing cable must be successfully pulled out from the existing conduit(s) by Glendale *Water & Power* work crews.
2. The existing empty service conduit(s) must pass a mandrel test which is performed by the customer/contractor in the presence of a Glendale *Water & Power* Construction Inspector. Roto-rooting of conduit(s) to clear conduit problem(s) will not be allowed.
3. If the existing conduit(s) passes the mandrel test, the new service cable must be successfully pulled into the existing conduit(s) by Glendale *Water & Power* work crews.
4. I understand that if the existing conduit(s) is of a type of material that does not meet Glendale *Water & Power's* current standards, then the existing underground conduit(s) cannot be used for the new service.
5. If the *existing* conduit system is exposed or at an improper depth, then I understand that I may be required to make corrections that would bring the system up to current standards.

I would also be responsible for maintaining the temporary electrical service to my house during the building of a new system if a temporary service installation cannot be provided and installed by Glendale *Water & Power*.

I agree to comply with all of the above written conditions that may be required from me and my contractor(s), in order to provide my home with an electrical service which complies with current Glendale *Water & Power's* Electric Construction Standards.

Signature: \_\_\_\_\_

Dated: \_\_\_\_\_

## Safety Person

Breaking into energized subterranean vaults, pull boxes or duct banks require the presence of a GWP safety person. **To coordinate this work, contact the GWP Construction Inspector (818) 548-3920, 48 hours in advance.**

## Installation of Structures

The customer is responsible for installations of service ducts and appurtenant structures for service from an overhead or underground line source, both on the customer's premises and in public right-of-way.

## Locations of Structures

GWP's approval is required in advance of construction for the locations and type of structures installed for GWP's use.

## Grounding

All grounding materials shall be furnished and installed by the contractor. Contact GWP Customer Service Engineering for information on specific installations.

## Temporary Service Connections

A service connection for temporary use during construction may be made from an underground source provided the customer installs the necessary structures and facilities at the customer's cost. To keep the temporary installation and removal costs to a minimum, the facilities for the permanent service should be completed to the fullest extent practicable.

A temporary conduit may be installed from a permanent subterranean pull box at the end of the run or in the run of the permanent service conduit. This temporary conduit which connects to a suitable temporary metering shall be installed by the customer and the required conductors are installed by GWP.

**See UG-DWG-005 and UG-DWG-006** for typical temporary underground service connections.

The customer shall pay the cost of installation and removal of temporary service connections and related equipment.

## Underground Service from an Overhead or an Underground Source

Any customer desiring the service conductors underground shall furnish and install at customer's expense all conduits or ducts, subterranean pull boxes or vaults, and risers on poles, as required by GWP, and as specified in these requirements. GWP will determine the number of conduit runs and the size of conduits installed in each case.

All secondary distribution subterranean pull boxes involve special requirements. Consult GWP for the special requirements. A distribution pull box is one that is intended for use by more than one customer.

## Maintenance

The customer shall maintain all conduits and substructures in private property and GWP will maintain all conduits and substructures in the public right-of-way.

## Service Conductors

GWP will, in all cases, determine the size, type and number of runs, of service conductors from GWP's lines to the terminating enclosure.

## Cost of Service

Secondary Service - The customer shall pay to GWP the cost of all material and labor hours required to install the service. **See GEN-104, Table 1** for a schedule of charges for Overhead, Underground, and Overhead to Underground Services.

## Pre-construction Conference

Materials and construction are subject to inspection and approval of GWP. Notify GWP's Construction Inspector at (818) 548-3920, 48 hours in advance of construction for a pre-construction conference. Contractor must also secure GWP authorization prior to obtaining an excavation permit for any work in the public right-of-way.

## Easement

Distribution conduit runs will require an easement to the City, whenever they cross private property, prior to electric service connection.

## **Excavation Permit**

When excavating in the public right-of-way, an excavation permit is required from City of Glendale, Public Works Department, Permit Services Center, telephone number (818) 548-3200, 633 E. Broadway, Room 101. Contractor shall notify Public Works Construction Inspector at (818) 548-3940, 48 hours in advance of the time when backfilling is to be done under this permit. The excavation permit shall be made available at the job site for review by the GWP Construction Inspector.

## **Resurfacing**

All necessary resurfacing in the public right-of-way is the total responsibility of the contractor, and must be to the satisfaction of the Public Works Inspector. All city property shall be restored to its original condition.

## **Existing Substructures**

The contractor shall verify all existing substructure information and dimensions in the public right-of-way. Any damage to these substructures will be the total responsibility of the contractor.

## **Field Change/Revisions/Plan Change**

If it is necessary to deviate from the approved substructure plan, the contractor shall duly notify the engineer, inspector or the authorized representative of GWP at (818) 548-3921 before implementing any changes. The engineer shall give a duly approved, revised written plan to the contractor which shall then become part of the approved plans. The contractor shall use the revised written plan when implementing a change/revision in the field.

## **Retaining Wall**

Where vaults, pull-boxes, or street light bases are installed adjacent to an embankment, retaining walls shall be installed in accordance with the grading plan or as required by GWP Construction Inspector.

## **SINGLE POINT OF SERVICE DELIVERY PER BUILDING**

Normally only one point of service delivery will be established for any single or multiple occupancy building (including condominiums in common tenancy). All terminating enclosures for services for each of the types, phase and voltage classes of load to be served shall be grouped at this location.

Exception: Where a building is more than 150 feet in length, additional points of service delivery may be established. Each such service point shall be metered separately from other service points.

Where GWP owned transformers are to be installed on the customer's premises, refer to the PRI section relative to service delivery.

## **SINGLE POINT OF SERVICE DELIVERY FOR EACH PREMISE**

Only one point of service delivery will be established for each lot or continuous premises on which one or more buildings are to be served. All terminating enclosures for services for each of the types and phase and voltage classes of load to be served shall be grouped at this location.

In cases where single premises are abnormally extensive in area, consult with GWP Customer Service Engineering to determine how service will be provided.



## LOCATION OF POINT OF SERVICE DELIVERY

The location of each point of service delivery must be approved by GWP in advance of construction. All terminating enclosures at a point of service delivery shall comply with the detailed requirements of **Location of Terminating Enclosures, see UG-104**. The following requirements will apply:

1. Secondary Service (240 volts)
  - a. Where GWP installs underground service cables from its overhead or underground lines to a point of service delivery on or in a building or structure, the point of service delivery shall be at or immediately adjacent to the building wall nearest and facing (1) the point at which the service duct enters the premises (2) the pole from which the service originates; and shall be as near as practicable to the corner of such wall which is accessible with a minimum length of service duct. For meter locations, **see MTR-105**. The point of service delivery may be in a pull box provided it is in a permanently accessible location approved by GWP.
  - b. Where GWP installs service cables from its lines to a point of service delivery at which the terminating enclosure is a wall mounted pull box, or the pull section of an outdoor switchboard, its location shall be approved by GWP.
2. Primary Service (4.16kV or 12.47kV)
  - a. GWP will install the service cable in all high-voltage services in accordance with the applicable provisions of its rules.

## Service Conduit Installation

The customer shall install any service duct in accordance with GWP's standards.

## Size and Number of Conduit(s)

Refer to GWP's service spot for information relative to the minimum conduit size and number acceptable to GWP. A duct with 3-inch nominal inside diameter is the minimum acceptable size for pedestal services and residential services. Unless specified by GWP.

## Service Conduit(s) Through Buildings

When the customer's terminating enclosure is within the building and GWP pulls cables to this point, the customer shall install a conduit encased in or under two inches of concrete.

When service conduits are encased in 2" or more of concrete, or under not less than 2" of concrete beneath a building or other structure, they are considered to be outside of the building by the National Electrical Codes. (230.6)

## Secondary Conduit(s)

Conduit(s) and sweep(s) shall be rigid galvanized or approved DB 100 plastic conduit and sweep per ANSI/ASTM F512 as last revised. Four inch conduit(s) shall have 48" and three inch conduits shall have 36" minimum radius rigid galvanized or schedule 80 plastic sweep at terminations. The riser sweeps on the pole shall be rigid galvanized, extended two feet above the finished grade. GWP shall designate the quadrant in which the riser conduit will be installed and the riser conduit will be installed by GWP construction crews. The contractor shall align and connect the riser sweep with the riser conduit installed by GWP. Minimum cover to be 30" in private property and 36" in public right-of-way. Conduits in public right-of-way shall be concrete encased as per **UG-103, page 4 of 4, Conduit Encasement**. Conduit encasement is not required if rigid galvanized conduit is used. Size and number of secondary conduits required will be specified in the service spot.

**Secondary Distribution Conduit(s) in Private Property**

Secondary distribution conduits(s) in private property shall be concrete encased as per **UG-103, page 4 of 4, Conduit Encasement**. Conduit encasement is not required if rigid galvanized conduit is used.

**Spare Secondary Conduit(s)**

All service spots will be designed with the minimum number of spare conduits required and the customer shall not obstruct any future entries into the distribution pull box or vault with concrete over pours.

**Future Conduit(s) or Riser(s)**

All future conduits, if required, shall be supplied by GWP and installed by the customer. These future conduits are required so all customers can have access to the underground and overhead distribution system.

If the installation of future service conduits is recommended, it is at the discretion of the owner of the project to install the conduits. These conduits will be clearly specified as recommended on service spot.

**Primary Conduit(s)**

Conduit(s) and sweep(s) shall be rigid galvanized or concrete encased approved DB 100 plastic per ANSI/ASTM F512 as last revised. Four inch conduit(s) shall have 48" and three inch conduits shall have 36" minimum radius rigid galvanized or schedule 80 plastic sweep at terminations. The riser sweeps shall be rigid galvanized, extended two feet above the finished grade. GWP shall designate the quadrant in which the riser conduit to be installed and the riser conduit will be installed by GWP construction crews. The contractor shall align and connect the riser sweep with the riser conduit installed by GWP. Minimum cover to be 36". Size and number of primary conduits required to be specified in the service spot.

Primary conduits shall be encased per **UG-103, page 4 of 4, Conduit Encasement**.

## Spare Primary Conduit(s)

A spare primary conduit or riser is only required for primary services 1200 amps, 480Y/277 or 2000 amps, 208Y/120 and larger. For services smaller than the above mentioned, a spare service conduit may be specified as recommended only.

## Length of Secondary Service Run

The maximum allowable length of duct between pull boxes is determined by the type and size of cables, the duct size, and the number of bends in the run. The following criteria must be taken into consideration for design of secondary runs:

- a) Service conduits which run up to 150 feet in length are acceptable if they contain no more than two 90 degree sweeps in public right of way and two 90 degree sweeps in private property.
- b) Service conduits which run up to 380 feet are acceptable with one 90 degree sweep in public right of way and two 90 degree sweeps in private property.

## Route of Conduits

The entire route of the duct installed must be approved by GWP.

## Pull Line and Mandrelling

Contractor shall install Muletape minimum 1,250lb strength with footage markings or 3/16" diameter polyethylene pull line in all conduits. All conduits must be mandrelled while the GWP construction inspector is present. Contractor shall install pull line ahead of time before pulling mandrel in the presence of a GWP Construction Inspector. Customer must notify GWP by calling (818) 548-3920, 48 hrs in advance.

## Conduit Termination

All conduits terminating in vaults and walls of pull-boxes shall be terminated as follows: PVC conduits require end bells and steel conduits require grounding end bushings. All conduits entering a pull-box from the bottom shall extend no more than 4" above the gravel. Conduits stubbed into lots for future use shall be capped at their terminations.

## Duct Bank Alignment

The entire duct bank shall be laid in parallel to finished grade to minimize deflections in the duct line. Deviation from this requirement must be approved by GWP Construction Inspector.

## Foreign Substructures

Electrical ducts shall be separated from other substructures by a minimum clearance of 12" horizontally when paralleling and 6" vertically when crossing. Public Works Engineering Department shall be consulted for minimum clearances requirements from sewer lines and storm drains.

## Curbs and Lot Corners

Street curbs shall be in place and property lines staked prior to substructure installation. Grade stakes with an offset distance from substructure centerline may be substituted for curbs.

## Conduit Encasement

If required, conduits shall be encased in a 3.0 sack concrete mix containing 3/8" pea gravel. A 2" separation between conduits and a minimum concrete envelope of 3" around the perimeter shall be maintained.

## Fiber Optic Conduit (Primary Services)

Conduit(s) shall be a minimum of 4" inside diameter and shall be placed at the top of the conduit bundle. Installation requirements are the same as discussed in "Primary Conduit(s)." Smaller diameter conduit may be substituted with GWP's prior approval.

**Terminating Enclosures**

A terminating enclosure shall be provided for all underground services. Terminating lugs for the load side of landings shall be supplied by the customer. Terminating lugs for the line side will be provided by GWP.

Every service terminating enclosure shall be in a permanently accessible location which is acceptable to GWP.

Whenever a terminating enclosure is within a single occupancy building and such building is divided into multiple occupancy, all sets of service entrance conductors shall be brought to a single terminating enclosure located as required for multiple occupancy buildings. See MTR-105, "Meter Locations".

The following are acceptable terminating enclosures as permitted in these requirements.

<b>Wall Mounted Pull-boxes</b>	<b>EUSERC DRAWING #315</b> <b>EUSERC DRAWING #343</b> <b>EUSERC DRAWING #344</b>
<b>Switchboard Pull Sections</b>	<b>EUSERC DRAWING #345</b> <b>EUSERC DRAWING #347</b>
<b>Safety Socket Boxes</b>	<b>EUSERC DRAWING #304</b> <b>EUSERC DRAWING #305</b>
<b>Meter post and pedestals</b>	<b>EUSERC DRAWING #308</b>
<b>Combination meter panels with Terminating Sections</b>	<b>EUSERC DRAWING #301</b>
<b>Combination Switchboard Service Section and Pull Section (with GWP Approval)</b>	<b>EUSERC DRAWING #327</b>
<b>Nonstandard Terminating Pull Sections for below ground level installations.</b>	<b>UG-DWG-011</b>

## High Voltage Terminating Enclosures

All services above 600 volts require special terminating enclosures. **See PRI Section.**

## Subterranean Type Fuse Terminating Pull Box

This type of service is not permitted.

## Wall Mounted Type Terminating Pull Boxes and Switchboard Pull Sections (Located on an Exterior wall)

Wall mounted service terminating pull boxes may only be used per GWP discretion. These pull boxes and switchboard pull sections shall be located on or recessed in an exterior wall of the building served, facing outward. The enclosure shall be permanently accessible without entering the building, shall not project into any driveway, walk, or public way and shall have access and working space in compliance with **UG-104, page 3 of 3 “Access to and Working Space in Front of Termination Enclosures”** and **MTR-110, page 3 of 4 “Working space Metering and Service Equipment”**. The bottom of the wall mounted enclosures shall not be less than 6 inches above grade (working space).

## Wall Mounted Type Terminating Pull Boxes and Switchboard Pull Sections (Located Inside a Building)

Terminating pull boxes and pull sections may be located inside a **commercial or industrial** building under the following conditions:


1. The service conduit shall be encased in not less than 2 inches of concrete or under a concrete floor at least 2 inches thick.
2. Wall mounted type pull boxes may only be used per GWP discretion. These pull boxes and switchboard pull sections may be at grade floor level or may be installed in a basement having a ceiling height of not less than 7 feet. All such installations shall comply with access and working space requirements and subject to the approval of GWP.

## **Access to and Working Space in Front of Termination Enclosures**

All terminating enclosures shall be provided 24 hour accessibility for installation and maintenance of GWP facilities. Access must be through walking space affording not less than 6'-6" height and 3 feet in width.

A permanent, level standing and working surface shall be provided. It shall be clear and unobstructed, at least equal to the width and height of the terminating enclosure space. The work space shall extend in front of all terminating enclosures and their housings as required by NEC. The working space shall be located in private property and in no case shall be located or extended in the public right of way. In no case shall the height of the clear space be less than 6'-8". The width shall not be less than 3 feet. **See UG-DWG-009** for clearances on non-residential service pedestals (0-200A).





#### Notes

1. When a residence is served from a front property line, the customer's service equipment shall be located as shown above (front portion of residence). When served from the rear property line, the service equipment shall be located as directed by GWP representative to provide maximum accessibility for maintenance and meter reading.
2. Contact GWP before locating service equipment. When service equipment is improperly located because GWP was not contacted in advance, the customer is responsible for all modifications.
3. Refer to Metering Equipment Chapter (MTR), MTR-105 for meter access and prohibited meter locations.
4. City of Glendale, Zoning approval may be required for new homes if service panel is placed on front face of buildings.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
1/13/14	1	CHANGED PULL BOX REQUIREMENT FROM "MAY BE" TO "IS" REQUIRED	CC	VMP	VA





REV. NO.  
DATE 07/01/98  
DRAWN BY P MEZA  
APPROVED BY:HRA

CITY OF GLENDALE WATER & POWER  
**TYPICAL SERVICE LATERAL INSTALLATION  
FOR SINGLE FAMILY RESIDENCE**

UG-DWG-001  
PAGE 1 of 1

CUSTOMER SERVICE ENGINEERING



#### Notes

1. Customer to furnish conduits, pull boxes, adapters, gutters, trench and backfill.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.




REV. NO.  
DATE 01/14/05  
DRAWN BY: P MEZA  
APPROVED BY: HRA


CITY OF GLENDALE WATER & POWER


*TYPICAL SERVICE COVERSION FROM  
OVERHEAD TO UNDERGROUND*

UG-DWG-002  
PAGE 1 of 1

CUSTOMER SERVICE ENGINEERING



	CITY OF GLENDALE WATER & POWER		
	REV. NO. DATE 01/14/05 DRAWN BY:P MEZA APPROVED BY:HRA	<i>TYPICAL RISER AT OVERHEAD DISTRIBUTION POLE</i>	UG-DWG-003 PAGE 1 of 1
	CUSTOMER SERVICE ENGINEERING		



# Notes

## Detail 1

1. A sweep must be permanently installed by the developer at the service entrance if the riser is recessed behind the outer wall or if the concrete foundation is poured in such a way as to effectively cause the riser to be recessed 4" or more. Sweeps shall be of PVC schedule 80 or RGC conduit as approved by the GWP Construction Inspector.
2. A 10 inch minimum side clearance is required measured from the center line of the meter(s) to any obstruction.
3. The exterior door must open a minimum of 90°.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.




REV. NO.  
DATE 01-14-05  
DRAWN BY: P MEZA  
APPROVED BY: HRA

## CITY OF GLENDALE WATER & POWER

### SERVICE ENTRANCE FOR RECESSED SERVICE APPLICATIONS

UG-DWG-004  
PAGE 1 of 1

CUSTOMER SERVICE ENGINEERING





#### Notes

1. GWP will furnish, install and connect the cables, between the meter and the hand-hole/pull box. GWP will make the connections up to the service point.
2. Customer to furnish all service equipment, excavate trench, and backfill.
3. Set post a minimum of 18 inches from main secondary cable trench.
4. Overhead conductors shall not be attached to this meter pole.
5. Refer to the NEC for main switch, ground fault circuit protection and grounding requirements.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.

	CITY OF GLENDALE WATER & POWER				
	REV. NO.	TEMPORARY SERVICE FROM A SECONDARY PULL BOX			UG-DWG-005
	DATE 01-14-05 DRAWN BY: P MEZA APPROVED BY: HRA	CUSTOMER SERVICE ENGINEERING			PAGE 1 of 1



**Notes:**

1. Service panel must be approved by City of Glendale, Public Works Building Section Inspector before the service cables are installed by GWP.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
7/1/09	1	PIGGY BACK DESCRIPTION	EN	PM	HRA






REV. NO.  
DATE 01-14-05  
DRAWN BY: BALUYOT  
APPROVED BY: HRA

CITY OF GLENDALE WATER & POWER

**PLUG-IN TEMPORARY (PIGGY BACK)  
SERVICE ADAPTER**

UG-DWG-006  
PAGE 1 of 1

CUSTOMER SERVICE ENGINEERING



DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
1/13/14	1	ADDED SWEEP RADIUS FOR 5" CONDUIT	CC	VMP	VA




REV. NO.  
DATE 01-14-05  
DRAWN BY: P MEZA  
APPROVED BY: HRA

CITY OF GLENDALE WATER & POWER

**RISER SWEEP INSTALLATION AT WALL, PAD OR ELECTRICAL PULL SECTION**

UG-DWG-007  
PAGE 1 of 1


CUSTOMER SERVICE ENGINEERING



#### Notes

1. Customer's service conduit installation is subject to the approval of GWP Construction inspector. Backfill and compaction shall comply with City of Glendale Public Works ordinances.
2. Four hundred (400) ampere service may require use of a larger conduit size.
3. A multiple meter service may require larger conduit than specified in Note 2. Consult GWP Customer Service Engineering Office for details.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.



REV. NO.  
DATE 01-14-05  
DRAWN BY: P MEZA  
APPROVED BY: HRA

CITY OF GLENDALE WATER & POWER

*SERVICE ENTRANCE FOR SINGLE  
FAMILY DWELLING SERVICE*

UG-DWG-008  
PAGE 1 of 1

CUSTOMER SERVICE ENGINEERING



## PEDESTAL INSTALLATION

- 1 All service pedestals shall be submitted to Glendale Water & Power Department for approval, and must meet City of Glendale and EUSERC standards for commercial use.
- 2 All pedestals shall have a meter socket and test blocks. This requirement applies regardless of whether or not the service will be metered or flat billed. This requirement does not restrict the use of 120 volts, 2-wire circuits on the load side of the meter socket.
- 3 All pedestals shall have a main switch and rated for 120/240 volt, 1Ø, 3 wire service.
- 4 Stainless steel pedestals are required in landscaped areas subjected to regular water sprinkler wetting.
- 5 The pedestal shall be installed so that its closed doors do not face the street or sidewalk, unless otherwise noted.
- 6 The pedestal foundation pad shall be 3" minimum above finished grade.
- 7 A 3'-0" working space with level 3" thick concrete pavement shall be provided in front and back of each service pedestal when it is located in parkway or any non-concreted area. Otherwise, an existing level concrete or asphalt pavement serves this purpose when it provides 3'-0" working space in front of each service pedestal door.
- 8 A 5/8" x 10'-0" long ground rod shall be provided in the load-side compartment of the service pedestal. It shall be driven into the ground so that it extends 6" above service pedestal foundation pad. See UG-DWG-009 page 3 of 4.
- 9 Glendale Water & Power will provide and affix one inch high self-stick and weatherproof labels on the front exterior of the pedestals for the service address.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
2/24/14	2	CHANGED GROUND ROD LENGTH TO 10'	CC	PM	VA



REV. NO.  
DATE 01-14-05  
DRAWN BY: P MEZA  
APPROVED BY: HRA

CITY OF GLENDALE WATER & POWER

*SERVICE PEDESTAL UNDERGROUND  
INSTALLATION STANDARDS*

UG-DWG-009  
PAGE 1 of 4

CUSTOMER SERVICE ENGINEERING


10 CLEARANCES:

- a) 2'-0" minimum clearance from service pedestal to back of curb.
- b) 5'-0" minimum clearance from riser conduit to service pedestal if there is no distribution pull box.
- c) 15'-0" minimum clearance from riser conduit to service pedestal if there is a distribution pull box.
- d) 4'-0" minimum clear passage space for pedestrians shall be maintained between service pedestal and other structures within sidewalk.


11 When no parkway exists, the pedestal may be installed in sidewalk if proper clearance is maintained, as specified in 10(d).

12 Pedestal shall not be installed at curb returns.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.

	CITY OF GLENDALE WATER & POWER	
	REV. NO. DATE 01-14-05 DRAWN BY: P MEZA APPROVED BY: HRA	SERVICE PEDESTAL UNDERGROUND INSTALLATION STANDARDS
	CUSTOMER SERVICE ENGINEERING	

UG-DWG-009 PAGE 2 of 4
---------------------------



DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
3/17/14	1	CHANGED LENGTH OF GROUND ROD FROM 8' TO 10'	CC	PM	VA



REV. NO.  
DATE 01-14-05  
DRAWN BY: P MEZA  
APPROVED BY: HRA


CITY OF GLENDALE WATER & POWER

SERVICE PEDESTAL UNDERGROUND  
INSTALLATION STANDARDS

UG-DWG-009  
PAGE 3 of 4

CUSTOMER SERVICE ENGINEERING

NOTE: NUMBERS IN CIRCLES REFER  
TO INSTALLATION NOTES.  
UG-DWG-009 (PAGES 1 & 2)



*PLAN VIEW*  
SCALE NONE

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
3/17/14	1	CHANGED LENGTH OF GROUND ROD FROM 8' TO 10'	CC	PM	VA




REV. NO.  
DATE 01-14-05  
DRAWN BY: P MEZA  
APPROVED BY: HRA


CITY OF GLENDALE WATER & POWER  
**SERVICE PEDESTAL UNDERGROUND  
INSTALLATION STANDARDS**

UG-DWG-009  
PAGE 4 of 4


CUSTOMER SERVICE ENGINEERING



**TYPICAL ASSEMBLY**  
(WITHOUT COVER)



**TYPICAL COVER**  
(NON TRAFFIC CONDITION)



**SECTION**

ALL COVERS SHOULD BE MARKED  
WITH THE WORD "ELECTRIC"  
RECESSED IN THE CONCRETE.

**NOTES:**

1. RADIUS ANGLE MAY BE REDUCED TO LESS THAN 90 DEGREES PROVIDING THE PROJECTED CENTER LINE OF THE CONDUIT CLEARS HANDHOLE OPENING.
2. TWO HOLDDOWN BOLTS TO BE SUPPLIED WITH EACH HANDHOLE.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
1/1/02	1	DRAWING NUMBER CHANGED	HRA	HRA	HRA




REV. NO. 1  
DATE 01-14-05  
DRAWN BY: JCW  
APPROVED BY: HRA

CITY OF GLENDALE WATER & POWER

**CONCRETE HANDHOLE/PULL BOX  
INSTALLATION (PARKWAY OR SIDEWALK)**

UG-DWG-010  
PAGE 1 of 1

CUSTOMER SERVICE ENGINEERING



SWITCHBOARD RATING (AMPERES)	MINIMUM ACCESS OPENING DIMENSION - SEE NOTE 3		
	PULL SECTION (W1)		ENTRANCE WIREWAY (W2)
	3-WIRE	4-WIRE	
0 - 400	18"	24"	18"
401 - 800	24"	24"	
801 - 1200	24"	30"	24"
1201 - 2000 (consult GWP)	30"	35"	


#### NOTES:

- For the purpose of these requirements, "nonstandard" means that the equipment arrangements represented above are not standard construction and require special ordering from manufacturers.
- Pull section and entrance wireway access cover panels shall be independent of other service equipment and removable without disturbing adjacent panels; seatable, provided with lifting handles, and limited to 9 square feet in area with a maximum width or length of 5 feet.
- The minimum access opening dimensions ("W1" and "W2") are measured between the inside edges of the left and right side return flanges.

**Note:** The actual enclosure outside dimension will be larger and will vary between manufacturers.

- Terminating facilities for GWP's service supply conductors shall be provided in all switchboard pull sections.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.
2/2/10	1	ADDED WINDOW HEIGHT AND REVISED SWITCHBOARD RATING	CC	VMP	VA

 <div>CITY OF GLENDALE WATER &amp; POWER</div>	CITY OF GLENDALE <i>WATER &amp; POWER</i>				
	REV. NO.	<i>NONSTANDARD TERMINATING PULL SECTION FOR BELOW GROUND LEVEL INSTALLATION</i>			UG-DWG-011 PAGE 1 of 2
	DATE 07/01/09				
	DRAWN BY A.PARRA				
APPROVED PM					
CUSTOMER SERVICE ENGINEERING					

5. The shaded area is reserved for the Department's service supply conductors. No conduits or customer wiring shall be installed in or routed through this area. No other conductors or ground connections shall be routed through or terminated in this area.

6. The terminating facilities shall be located as far forward (close to the pull section access cover panels) as possible to provide for adequate cable bending radius.

**Note:** The minimum clearance from any energized part to a removable access cover panel shall be 4 inches. This dimension may be reduced to 1-1/2 inches if a removable safety barrier is provided by the manufacturer.

7. Cross-bussing of a different phase or potential installed behind or below any terminating position shall be fully insulated or barriered. Insulating barriers shall be a rigid, nonflammable material rated for the serving voltage, resistant to ARC tracking, resistant to puncture or damage by impact, and attached with nonconducting fasteners.

8. Conduits shall not enter the side of any pull section without the express permission of the Department. Side entry conduits may require a wide pull section enclosure to assure adequate spacing for cable bending radius.

9. The edges of the cable window between the entrance raceway and the pull section shall be rounded or otherwise protected to prevent damage to the service supply conductors.

**Note:** The width of the cable window shall provide direct access to each specified cable terminating position without bending around the window edges.

DATE	REV.	DESCRIPTION	BY	CHK'D	APP.



REV. NO.  
DATE 07/01/09  
DRAWN BY A.PARRA  
APPROVED PM

*NONSTANDARD TERMINATING PULL SECTION  
FOR BELOW GROUND LEVEL INSTALLATION*

UG-DWG-011  
PAGE 2 of 2

CUSTOMER SERVICE ENGINEERING