



WQR.19

City of Glendale Water & Power 2018 Water Quality Report to our Customers

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

The water delivered to you by Glendale Water & Power continuously passes tough State and Federal quality standards. This booklet is a detailed report on the water we delivered to you in 2018.



State and Federal Regulation

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Customer Participation and Assistance

Comments from the public are welcome and may be presented at the Glendale Water & Power Commission meetings held the first Monday of each month, at 4:00PM, in the Glendale City Council Chambers, 613 E. Broadway. Please write to: James Saenz, Water Quality Manager, Water Quality Section, Glendale Water & Power 141 N. Glendale Ave., Level 4, Glendale, CA 91206 or call (818) 548-2011. This report can also be downloaded on GWP's website www.GlendaleWaterAndPower.com

A Message from General Manager Stephen M. Zurn



Glendale Water & Power (GWP) is committed to the safety of the water served to the residents of Glendale and in 2018 the City's water continued to meet all federal, state and local water quality standards. Maintaining safe and reliable water service requires a team of trained professionals focused on service to the community. The City of Glendale's water system is primarily regulated

by the State Water Resources Control Board, Division of Drinking Water. The State rates each water system based on the complexity of the distribution system and the complexity of the treatment processes needed for the water served in the system. Glendale's distribution and treatment systems are rated at the highest level of complexity. To comply with these requirements GWP's Water Division staff dedicate personal time to take specialized training courses in Water Distribution and Water Treatment in order to prepare for State examinations to obtain individuals certifications and to maintain their existing certifications through continuing

education. In 2018 alone, 10 Water Division Staff members obtained either their first certification or a new higher level of certification, and four additional staff members reached the highest level of individual certification available.

To ensure the continued safety of Glendale's water GWP's staff take more than 5,700 water quality samples every year and they monitor the testing and compliance of over 2,200 backflow prevention assemblies that help ensure contamination does not enter the water system. In addition to these ongoing water quality activities, GWP's staff perform routine maintenance of the tanks and reservoirs in Distribution System by periodically draining them in order to clean and disinfect them and to perform an engineering inspection of the coatings of tanks and of the roofs of the reservoirs. GWP is Glendale owned and Glendale focused, and this focus extends to GWP's team of water professionals and the work they do to ensure the quality of all of the City's sources of water.



Frequently Asked Questions

My drinking water is reddish brown. Why?

Reddish-brown water can be caused by rust dislodged from the drinking water pipes in the street, those leading to, or inside, your home, or from your hot water tank. If you are having trouble and your neighbors are not, then the color is likely originating somewhere in your plumbing system. Let your water run until it clears up before using it.

Should I install a home water treatment device?

This is a personal decision. These devices are not needed to make the water meet federal, state, or local standards. In fact, if the devices are not properly maintained, they may cause problems of their own. You may consider a home treatment device if you desire to change the taste of your water.

How is the inside of a pipe cleaned after a water main break?

After the work is done, the inside of the pipes are disinfected with a chlorine solution to kill off germs. In some cases, water is flushed through the main at a high velocity by opening a fire hydrant which also allows the water main to be cleaned.

Why do GWP crews let water run down the street?

One way GWP maintains water quality is by cleaning pipelines using a flushing process to clean out sediment and minimize the potential for stagnant water. This process maintains disinfectant residuals and reduces the chances of bacterial growth in the water distribution system. Pipeline cleaning is an important, routine process and a non-wasteful, beneficial use of water.

My water often looks cloudy when taken from a faucet and then clears up. Why?

The cloudy water is caused by tiny air bubbles. After a while, the bubbles rise to the top and are gone. The cloudiness occurs more often in the winter when the drinking water is cold.

How can I find out if my water is supplied through lead pipes?

Glendale Water and Power's water mains are not made of lead. Most of our water mains are cast iron or steel. Using lead piping in homes has been banned since 1986 and is unlikely to be found in newer homes. In older homes, the pipes might be made of lead. Joints on lead pipes are very bulky in comparison to the neat fittings of copper and galvanized iron. If you are in doubt, please call a plumber to evaluate your plumbing system.

Why does my water smell like a rotten egg?

The most common cause of the rotten egg or sewage smell is from the gases released by bacterial growth in drain pipes. When you run your faucets, the water enters the drain pipe and forces these gases out, resulting in the smell. To determine if the smell is coming from the sink drain or the water, fill a glass with water, take it into another room and smell the water in the glass. If you do not smell the same odor from the water in the glass, then the odor is coming from the drain.

Why does my water smell like chlorine?

State and Federal regulations require that water utilities, including GWP, maintain a disinfectant residual throughout the distribution system. The purpose is to prevent water-borne illnesses by suppressing the growth of bacteria and other potential contaminants. GWP, like many other utilities, uses chlorine and chloramines to comply with these requirements. You may, at times, experience a chlorine taste or odor.



Cross-Connection Control Program

To protect drinking water systems from potential contamination, State law requires that utilities like GWP, maintain an effective Cross-Connection Control Program. A cross-connection can occur when a potable water line is directly or indirectly connected to a non-potable supply. Regulations require installation of backflow prevention devices at all locations where actual or potential cross-connections exist. An unprotected or inadequately protected cross-connection could contaminate the City's drinking water supply. Examples of potential cross-connection include fire

sprinklers, lawn irrigation, cooling systems and high pressure boilers. Implementing an effective cross-connection control program involves conducting facility inspections, evaluating the degree of potential hazard to public health, identifying the appropriate protection device, and providing training for onsite supervisors. Once devices are installed, there is a need for regular inspections and testing to ensure their proper operation as well as maintenance of accurate and up-to-date records. Glendale has never experienced contamination due to a cross-connection.



Recycled Water

The drought in the late 1980's paved the way for Glendale to develop an alternative source of water for non-potable uses. This alternative source is recycled water. Within Glendale, we have two separate water systems, one for drinking water and one for recycled water. Recycled water is domestic wastewater that undergoes extensive treatment. Glendale's supply of recycled water comes from the Los Angeles/Glendale Water Reclamation Plant which produces 14 million gallons of recycled water per day. Even though the end product of all of this treatment meets Federal and State drinking water standards, recycled water cannot be used for human consumption. Glendale's recycled water system helps minimize the impacts of drought and helps conserve our valuable sources of drinking water. Currently, recycled water use in Glendale is 7% of the total annual water used. GWP has 85 service connections that provide recycled water for public area irrigation, cooling towers, street cleaning, dust abatement, and flushing urinals and toilets in several dual-plumbed buildings. Glendale businesses and agencies using recycled water save significant costs over the use of drinking water. As the importance of water conservation becomes greater than ever, increasing our use of recycled water will improve our chances of meeting our water conservation goals while still meeting the water needs of all our customers. This will also reduce the costs of purchasing imported water and help Glendale become less dependent on imported sources of water.

Acronyms and Abbreviations

- cu = color units
- DLR = Detection Limits for purposes of reporting
- DPH = Department of Public Health
- DDW = Division of Drinking Water
- MCL = Maximum Contaminant Level
- MCLG = Maximum Contaminant Level Goal
- mg/L = milligrams per liter
- MRDL = Maximum Residual Disinfectant Level
- MRDLG = Maximum Residual Disinfectant Level Goal
- MWD = Metropolitan Water District of Southern CA
- NA = Not Analyzed
- ND = None Detected
- NL = Notification Level
- NS = No Standard
- NTU = Nephelometric Turbidity Units
- pCi/L = picoCurries per liter
- PHG = Public Health Goal
- ppb = parts per billion
- ppm = parts per million
- ppt = parts per trillion
- TON = Threshold Odor Number
- TT = Treatment Technique

Footnotes

- a) Aluminum has a secondary MCL of 200 ppb.
- b) Standard is for Radium-226 and -228 combined (calculated).
- c) Total coliform MCL: No more than 5% of the monthly samples may be total coliform-positive.
- d) Lead and Copper Rule compliance based on 90th percentile of all samples being below the Action Level. Samples were taken from 54 customer taps. Testing is required every three years. This data was collected in 2017. Next testing is in 2020. In 2018, GWP conducted Lead testing at 25 schools per the request of Glendale Unified School District.
- e) Copper has a secondary MCL of 1000 ppb.
- f) Analysis was on water before blending with MWD supply.

Nitrate

Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider. Glendale's water is tested at the source for contamination then treated to maintain levels below the MCL to ensure the water delivered to our customers is safe to drink.

Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. GWP is

- g) Compliance is based on Locational Running Annual Average (LRAA) for the stage 2 DBPR. "Citywide Average" represents highest LRAA.
- h) Hardness in grains/gallon can be found by dividing ppm by 171.
- i) For GWP sources, data represents the amount of naturally occurring fluoride. For MWD sources, data is after fluoride added at MWD treatment plant. Glendale's distribution system fluoride levels were monitored in 2018 - range 0.38 ppm - 0.73 ppm with an average of 0.61 ppm.
- j) Chlorate has a DDW Notification level of 800 ppb. Chlorate is a by-product of liquid chlorine. MWD range results were given distribution system wide.
- k) Water from the Foothill Well is blended with system water, actual level of nitrate in water served ranged between ND and 4.6 ppm, with an average of 2.3 ppm.
- l) Al < 10.0 = Highly aggressive and very corrosive water. Al ≥ 12 = Non-aggressive water. Al 10.0 - 11.9 = Moderately aggressive water.
- m) Compliance was based on RAA. Bromate was tested at effluent of Jensen (i) and Weymouth (ii) Treatment Plants where ozone is used as a disinfectant.
- n) While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.
- o) The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. Radiological sampling was last conducted in June 2014.
- p) Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of water quality. High turbidity can hinder the effectiveness of disinfectants.

responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>. Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and/or flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the USEPA Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

DETECTED CONTAMINANTS AT GLENDALE'S WATER SOURCES												
	Units	State MCL	PHG or [MCLG]		MWD Weymouth Plant	MWD Jensen Plant	Glendale Treatment Plant	Glorietta Well 3	Glorietta Well 4	Glorietta Well 6	Foothill Well	Major Sources of Contaminants in Drinking Water
ORGANIC CHEMICALS												
Tetrachloroethylene (PCE)	ppb	5	0.06	Range	ND	ND	ND	1.8 - 2.3	ND - 0.8	0.9 - 1.1	0.52 - 0.64	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
				Average				2.1	0.5	1.0	0.60	
INORGANIC CHEMICALS												
Aluminum (a)	ppb	1000	600	Range	ND - 220	ND - 75	ND	ND	ND	ND	ND	Residue from some water treatment process; natural deposits erosion
				Average	105	ND						
Arsenic (n)	ppb	10	0.004	Range	ND	ND	ND - 1.0					Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
				Average			0.65	0.5	0.4	0.5		
Barium	ppm	1	2	Range		ND	64 - 91					Discharges of oil drilling waste and from metal refineries; erosion of natural deposits
				Average	0.12		75.9	0.12	0.13	0.11		
Chromium, Total	ppb	50	[100]	Range	ND	ND	2.6 - 6.3					Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits
				Average			4.8	ND	ND	ND		
Fluoride (i)	ppm	2	1	Range	0.6 - 0.9	0.4 - 0.8		0.16 - 0.20	0.18 - 0.22	0.18 - 0.21	0.16 - 0.20	Erosion of natural deposits; water additives that promotes strong teeth; discharge from fertilizer and aluminum factories
				Average	0.7	0.7	0.35	0.15	0.18	0.16	0.18	
Nitrate (As N)	ppm	10	10	Range	ND	0.5	4.3 - 5.9	7.8 - 8.8	5.9 - 7.3	8.5 - 9.4	9.6 - 11	Runoff and leaching from fertilizer use septic tank and sewage; natural erosion
				Average			5.2	8.5	6.6	8.9	10 (k)	
RADIOLOGICALS												
Gross Alpha Particle Activity	pCi/L	15	[0]	Range	ND	ND - 3	ND - 5.9					Erosion of natural deposits
				Average			4.4	5.2	6.6	3.4	3.9	
Gross Beta Particle Activity	pCi/L	50	[0]	Range	ND	ND	ND - 8.2	NA	NA	NA	NA	Decay of natural and man-made deposits
				Average			4.8					
Uranium	pCi/L	20	0.43	Range	ND	ND - 1	ND					Erosion of natural deposits
				Average		ND		5.6	9.4	6.3	3.6	
REGULATED CONTAMINANTS WITH SECONDARY MCLS												
Chloride	ppm	500	NS	Range	96 - 97	54 - 57	50 - 67	110 - 130	80 - 140	99 - 120	58 - 62	Runoff/leaching from natural deposits; seawater influence
				Average	96	56	62	116	121	107	60	
Color	cu	15	NA	Range	ND - 1	ND - 1	ND	ND	ND	ND	ND	Naturally occurring organic materials
				Average	ND	ND						
Iron	ppb	300	NA	Range	ND	ND	ND	ND - 36	ND	ND	ND	Leaching from natural deposits; industrial waste
				Average				24				
Manganese	ppb	50	NL = 500	Range	ND	ND	ND - 4.9	0.5 - 1.5	ND - 0.24	ND - 0.35	ND	Leaching from natural deposits; industrial waste
				Average			1.6	0.9	0.02	0.26		
Odor	TON	3	NS	Range		1 - 4	1					Naturally occurring organic materials
				Average	3	2	1	1	1	1	1	
Specific Conductance	uS/cm	1600	NA	Range	897 - 1010	428 - 444	900	1000 - 1100	1100 - 1200	980 - 1100	720 - 760	Substances that form ions in water; seawater influence
				Average	954	436		1042	1108	1015	738	
Sulfate	ppm	500	NS	Range	190 - 236	43 - 46	100 - 170	140 - 170	97 - 170	140 - 170	82 - 93	Runoff/leaching from natural deposits; industrial waste
				Average	213	44	148	152	146	154	87	
Total Dissolved Solids (TDS)	ppm	1000	NS	Range	553 - 639	239 - 244	540 - 620	580 - 700	640 - 720	540 - 680	320 - 480	Runoff/leaching from natural deposits; seawater influence
				Average	596	242	580	643	679	635	441	
Turbidity	NTU	TT	NS	Range	ND	ND	ND - 0.39	ND	ND	ND	ND	Soil runoff
				Average			0.21					

UNREGULATED CONTAMINANTS DETECTED AT GLENDALE'S WATER SOURCES

	Units	Noti- fication Level	State DLR [PHG]		MWD Weymouth Plant	MWD Jensen Plant	Glendale Treatment Plant	Glorietta Well 3	Glorietta Well4	Glorietta Well6	Foothill Well	Major Sources of Contaminants in Drinking Water
CONTAMINANTS WITH NO MCLS												
Boron	ppb	1,000	100	Range Average	130	140	170 - 210 190	NA	NA	NA	NA	Runoff/leaching from natural deposits; industrial wastes
Chlorate (J)	ppb	800	20	Range Average	32	29	59 - 110 97	NA	NA	NA	NA	By-product of drinking water chlorination; industrial processes
Chromium VI	ppb		0.02	Range Average	ND	ND	2.9 - 6.6 5.0 (f)	0.27	0.38	0.33	1.4 1.4	Runoff and leaching from natural deposits; discharge from industrial waste factories.
1,4 - Dioxane	ppb	1	1	Range Average	NA	NA	ND - 1.1 1.1	NA	NA	NA	NA	Solvent used in a number of industrial and commercial applications.
N-Nitrosodimeth- ylamine (NDMA)	ppt	10	2	Range Average	2.2	ND	ND	NA	NA	NA	NA	By-product of drinking water chloramination; industrial processes
Vanadium	ppb	50	3	Range Average	ND	ND	3.4 - 5.7 4.7	NA	NA	NA	NA	Naturally-occurring; industrial waste discharge

LEAD AND COPPER RULE (d)

	Units	Action Level	PHG	No. of Samples	90th Percentile	No. of sites exceeding action level	Major Sources of Contaminants in Drinking Water
SAMPLES FROM CUSTOMERS' TAPS (COLLECTED EVERY 3 YEARS)							
Copper (e)	ppb	1300	170	54	170	0	Internal corrosion of household pipes; erosion of natural deposits; wood preservative leaching
Lead	ppb	15	0.20	54	ND	0	Internal corrosion of household pipes; discharges from industrial manufacturer; erosion of natural deposits

CITYWIDE SAMPLING

	Units	State MCL [MRDL]	MCLG [MRDLG] (PHG)	Citywide Average	Range	Major Sources of Contaminants in Drinking Water
SAMPLES FROM DISTRIBUTION SYSTEM						
Total Coliform Bacteria	%	5.0 (c)	0	0.29	0.0 - 1.05	Naturally present in the environment
Total Trihalomethanes (TTHM) (g)	ppb	80	NS	23	9 - 35	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (g)	ppb	60	NS	4.2	ND - 7.8	By-product of drinking water disinfection
Total Chlorine Residual	ppm	[4]	[4]	1.24	0.00 - 3.0	Drinking water disinfectant added for treatment
Bromate (m)	ppb ppb	10 10	(0.1) (0.1)	5 (i) 5.2 (ii)	ND - 10 ND - 6.4	By-product of drinking water ozonation

WATER CONSTITUENTS OF INTEREST TO THE PUBLIC

	Units		MWD Weymouth Plant	MWD Jensen Plant	Glendale Treatment Plant	Glorietta Well 3	Glorietta Well 4	Glorietta Well 6	Foothill Well
Alkalinity	ppm	Range	107 - 117	68 - 76	190	170 - 180	200 - 220	160 - 180	150 - 170
		Average	112	72	190	178	210	171	165
Calcium	ppm	Range	57 - 69	19 - 21	94	95 - 111	101 - 116	95 - 111	69 - 79
		min	63	20	94	103	108	102	74
Corrosivity (I) Aggressive Index	Al	Range	12.2 - 12.5	12	13	11.2 - 11.7	11.4 - 11.9	11.5 - 11.8	11.2 - 11.6
		Average	12.4		13	11.5	11.7	11.6	11.5
Corrosivity Saturation Index	SI	Range	0.43 - 0.57	0.26 - 0.28	NA	NA	NA	NA	NA
		Average	0.50	0.27	NA	NA	NA	NA	NA
Hardness (h)	ppm	Range	233 - 274	84 - 94	340	382 - 441	406 - 466	377 - 436	269 - 307
		Average	254	89	340	408	431	403	287
Magnesium	ppm	Range	23 - 26	9.5 - 9.9	26	35 - 40	37 - 43	34 - 38	24 - 27
		Average	24	9.7	26	37	39	36	25
pH	pH Units	Range	8.1 - 8.2	8.4 - 8.5	7.7 - 8.3	6.1 - 7.7	6.0 - 7.4	6.4 - 7.4	6.3 - 7.5
		Average	8.1	8.5	8.1	6.9	6.9	6.9	6.9
Potassium	ppm	Range	4.4 - 5.0	2.4 - 2.5	3.9	3.0 - 3.8	3.6 - 4.3	3.2 - 4.0	4.0 - 4.7
		Average	4.7	2.4	3.9	3.3	3.9	3.5	4.2
Sodium	ppm	Range	94 - 103	45 - 46	54	44 - 50	47 - 53	40 - 47	29 - 33
		Average	98	46	54	46	50	43	31
Total Organic Carbon (TOC)	ppm	Range	2.1 - 2.8	2.0 - 2.6	0.46 - 3.2	NA	NA	NA	NA
		Average	2.4	2.6	1.6	NA	NA	NA	NA

Water Quality Terms in This Report

Maximum Contaminant Level (MCL):

The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG):

The level of a Contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.

Public Health Goal (PHG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the CalEPA.

Primary Drinking Water Standard (PDWS):

MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Maximum Residual Disinfectant Level (MRDL):

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG):

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Regulatory Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Source Water Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, come from gas stations, urban storm water runoff, agricultural application, and septic systems.

Radioactive Contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

Disinfection By-Products, which include Trihalomethanes (THMs) and Haloacetic Acids (HAAs), are generated by the interaction between naturally occurring matter and disinfectants, such as chlorine.



Sources of Glendale's Water

In 2018 Glendale Water and Power delivered 7.7 billion gallons of potable water to our customers. 67% was purchased from the Metropolitan Water District, after being imported and treated from Northern California and the Colorado River. 33% comes from local groundwater sources extracted from the Verdugo and San Fernando Basins. In addition, 6% of total water used in 2018 was recycled water delivered by the Los Angeles-Glendale Water Reclamation Plant. The plant's highly treated waste water meets or exceeds the water quality standards for recycled water and is used ONLY for irrigation and industrial processes.

Important Information for People with Compromised Immune Systems

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Explanation Regarding Contaminants

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).



Your Trusted Community Utility

Glendale Water & Power
141 North Glendale Ave., Level 4
Glendale, CA 91206

WQR.19

City of Glendale Water & Power 2018 Water Quality Report to our Customers

Follow us on:

 [COGwaterpower](#)  [GlendaleWaterAndPower](#)

This information is very important. Please have someone translate it for you.

Esta informacion es muy importante. Por favor pidale a alguien que se lo traduzca.

Այս տեղեկությունը շատ կարևոր է: Խնդրում ենք, որ մեկին թարգմանել տաք այն:

此資訊十分重要。請您找人幫您翻譯。

यह सूचना अत्यंत ही महत्त्वपूर्ण है। कृपया किसी से इसका अनुवाद करा लीजिए।

これは非常に重要な情報です。どなたかに翻訳をお願いしてください。

이 정보는 매우 중요합니다. 누군가에게 번역해달라고 하십시오.

Napakahalaga ang impormasyon na ito. Mangyaring ipasalin ninyo para sa inyong pang unawa.



Glendale Water and Power

Glendale Water and Power (GWP) water was established in 1914. GWP provides water service to almost all residential, commercial and industrial consumers located within the incorporated areas of the City. GWP is the retail provider of water service to all consumers in the city except for a small area in the northern portion served by Crescenta Valley Water District. GWP currently has approximately 34,181 service connections within 31 square miles. The potable water system has seven main pressure zones and consists of 395 miles of water mains, 28 pumping stations, 28 reservoirs and tanks, and the Glendale Water Treatment Plant.